

Job Name _____ Location _____ Date _____
 Purchaser _____ Engineer _____
 Submitted to _____ For Reference Approval Construction
 Unit Designation _____ Schedule # _____



Specifications				
Indoor Unit			MISAW3209	
Capacity	Cooling	Btu/h	9000 9000	
	Heating	Btu/h		
Electric Data	Power Supply	V~Hz/Ph	208~230,60,1	
	Input Current	A	0.13	
Indoor Unit	Air Flow Rate (Tu/Hi/Mi/Lo)	Cooling	CFM	353/312/282/247
		Heating		353/324/288/247
	Sound Pressure Level	dB(A)		40/38/35/30
	Net Dimensions		inch	31.02×7.80×11.50
			mm	788×198×292
	Packing Dimension (Panel)		inch	34.65×11.42×14.57
			mm	880×290×370
Net/Gross(body)		lbs	17.60/22.00	
Piping Diameter	Liquid Side	In.[mm]	1/4[6.35]	
	Gas Side	In.[mm]	3/8[9.52]	
	Drainage	In.[mm]	2/3[16.9]	

Dimensions

Indoor Unit
MISAW3209

